

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7125-0553:106

Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Space Age Electronics, Inc. 406 Lincoln Street, Marlborough, MA 01752
*Contact: Conrad Zukowski (508) 485-0966

DESIGN: Models C15/75 (15/75cd), C30/75 (30/75cd), C75 (75cd) and C110 (110cd) strobe lights.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/strobe rating, and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible devices and fire alarm control units. For wall mounting and indoor use only.

*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 4, 2001**

Listing Expires **June 30, 2002**

Authorized By: **BEN HO**, Supervising Deputy
Program Manager